

Electromagnetic compatibility – Guidance and manufacturer's declaration

IEC 60601-1-2

Models:

PARI SINUS 2 (Type 128) PARI BOY (Type 130) PARI COMPACT2 (Type 152) OEM Kompressor (Type 430)

Information for subject matter experts on Electromagnetic Compatibility (EMC)

1 INFORMATION FOR THIS DOCUMENT

This document is intended exclusively for qualified personnel for EMC.

2 ESSENTIAL PERFORMANCE

There are no essential performance characteristics according to the risk assessment.

3 ELECTROMAGNETIC ENVIRONMENT

The device¹ is intended for use in the electromagnetic environment specified below. The customer or the user of the device¹ should assure that it is used in such environment.

Emission test

Emission test	Compliance	Electromagnetic environment – Guidance
RF emissions CISPR 11	Group 1	The device ¹ uses RF energy only for its internal function. Therefore, its RF-emission is very low and not likely to cause any interference nearby electronic equipment.
	Class B	The device¹ is suitable for use in all establishments, including domestic establishments and those directly connected to the public low-voltage power supply network that supplies buildings used for domestic purposes.
Harmonic emissions IEC 61000-3-2	Class A	
Voltage fluctuations / flicker emissions IEC 61000-3-3	Passed	

Devices under test: compressors PARI SINUS2 (Type 128), PARI BOY (Type 130), PARI COMPACT2 (Type 152), OEM Kompressor (Type 430).

Immunity test

Immunity test	IEC 60601 test level	Compliance level	Electromagnetic environment – Guidance
Electrostatic discharge (ESD) IEC 61000-4-2	Contact: ±8 kV Air: ±15 kV	Contact: ±8 kV Air: ±15 kV	Floors should be wood, concrete or ceramic tile. If floors are covered with synthetic material, the relative humidity should be at least 30 %.
Electrical fast transient / burst IEC 61000-4-4	5/50 ns, 100 kHz, ±2 kV	5/50 ns, 100 kHz, ±2 kV	Mains power quality should be similar to that of a typical commercial or hospital environment.
Surge IEC 61000-4-5	1.2/50 (8/20) µs LtL: ±1 kV LtG: ±2 kV	1.2/50 (8/20) µs LtL: ±1 kV LtG: ±2 kV	Mains power quality should be similar to that of a typical commercial or hospital environment.
Voltage dips, short interruptions and voltage variations on power supply input lines IEC 61000-4-11	$\begin{array}{l} 0 \ \% \ U_T \\ \text{for } 0.5 \ \text{cycle} \\ (1 \ \text{phase}) \\ 0 \ \% \ U_T \\ \text{for } 1 \ \text{cycle} \\ 70 \ \% \ U_T \\ \text{for } 25/30 \ \text{cycles} \\ (50/60 \ \text{Hz}) \\ 0 \ \% \ U_T \\ \text{for } \\ 250/300 \ \text{cycles} \\ (50/60 \ \text{Hz}) \\ \end{array}$	$\begin{array}{l} 0 \ \% \ U_{T} \\ \text{for } 0.5 \ \text{cycle} \\ (1 \ \text{phase}) \\ 0 \ \% \ U_{T} \\ \text{for } 1 \ \text{cycle} \\ 70 \ \% \ U_{T} \\ \text{for } 25/30 \ \text{cycles} \\ (50/60 \ \text{Hz}) \\ 0 \ \% \ U_{T} \\ \text{for} \\ 250/300 \ \text{cycles} \\ (50/60 \ \text{Hz}) \end{array}$	Mains power quality should be similar to that of a typical commercial or hospital environment. When the user of the device¹ requires continuous function in the event of disruption of supply, it is recommended the device¹ is operated from an uninterruptible power supply or battery.
Power frequency (50 Hz / 60 Hz) magnetic field IEC 61000-4-8	30 A/m	30 A/m	Power frequency magnetic fields should be at levels characteristic of a typical location in a typical commercial or hospital environment.
Conducted RF IEC 61000-4-6 Amplitude modulated	150 kHz − 80 MHz 3 V ISM and amateur radio bands 6 V ⊠ 80 % / 1 kHz	150 kHz − 80 MHz 3 V ISM and amateur radio bands 6 V ⊠ 80 % / 1 kHz	WARNING: Portable RF communications equipment (including peripherals such as antenna cables and external antennas) should be used no closer than 30 cm (12 inches) to any part of the device ¹ , including cables, specified by the manufacturer. Otherwise, degradation of the performance of this equipment could result.

Immunity test	IEC 60601 test level	Compliance level	Electromagnetic environment – Guidance
Radio-frequency electromagnetic field Amplitude modulated	IEC 61000-4-3	80 MHz − 2.7 GHz ⊠ Home Healthcare (10 V/m) ⊠ Prof. Healthcare (3 V/m) ⊠ 80 % / 1 kHz	WARNING: Portable RF communications equipment (including peripherals such as antenna cables and external antennas) should be used no closer than 30 cm (12 inches) to any part of the device ¹ , including cables, specified by the manufacturer. Otherwise, degradation of the performance of this equipment could result.
Proximity fields from RF wireless communications equipment	IEC 61000-4-3	380 – 390 MHz 27 V/m; PM 50 %; 18 Hz 430 – 470 MHz 28 V/m; (FM ±5 kHz, 1 kHz sine) PM; 18 Hz 704 – 787 MHz 9 V/m; PM 50 %; 217 Hz 800 – 960 MHz 28 V/m; PM 50 %; 18 Hz 1700 – 1990 MHz 28 V/m; PM 50 %; 217 Hz 2400 – 2570 MHz 28 V/m; PM 50 %; 217 Hz 5100 – 5800 MHz 9 V/m; PM 50 %;	WARNING: Portable RF communications equipment (including peripherals such as antenna cables andexternal antennas) should be used no closer than 30 cm (12 inches) to any part of the device ¹ , including cables, specified by the manufacturer. Otherwise, degradation of the performance of this equipment could result.

©2023 PARI GmbH Spezialisten für effektive Inhalation, 041D0623-A 2023-11-30



